

## Why use Desiccant Dehumidification in Ice Arenas?

With the explosion of popularity of hockey and figure skating, most ice arena operators have endeavored to extend their operating season. This exacerbates problems caused by high ambient humidity. Without an effective dehumidification system, moisture-laden air leaking into the arena cools to its dewpoint and makes fog, dripping and other serious problems for the facility. In effect, the ice sheet itself becomes the dehumidifier, causing moisture to first condense (fog) and then freeze. The rink chiller is typically the most expensive component to operate in recreational facilities, and this moisture load causes it to run much more than it would without this burden.

Before inexpensive desiccant dehumidifiers became available, it was common to find a pair of 7-1/2 to 12 ton packaged refrigeration dehumidifiers in ice arenas. When applied to a very tight building with virtually no ventilation, the more visible effects of high humidity could be reduced. This was universally accepted to be a marginal solution, however.

Climate by Design International has specialized in applying Desiccant Dehumidifiers to Ice Arenas for over 25 years. Our first desiccant system replaced a system comprised of a cold coil fed with Glycol from the rink chiller and a hot water coil used to reheat the air. The customer had complained of limited dehumidification in the spring, summer and fall, coupled with high energy costs associated with the low temperature chiller. This was predictable since a cold-coil/re-heat scheme simply cannot achieve dewpoints low enough to arrest condensation on the cold ice sheet. This is true of both brine coils and DX packaged dehumidification units.

A properly sized desiccant system is the way to condition an ice arena to electron condensation because it is the low humidity air; typically 10 on fuel pricing and availadenergy savings for the results.

## **DESIGN CONSIDER**

## Sizing a desiccan

calculate the deh requirements of requirements. C typically require Code, requiring based on the siz

Outside air is imporsed to be represented the following standards depair ventilation volumes, since for require more mechanical equipment with the budget. Other significant accommodated include leaky building of people, doors and resurfacer operations.

For a typical recreational ice arena, a desiccant syste. to maintain approximately 35°F dewpoint in the arena. Removing water vapor with a desiccant unit before it can affect the ice surface relieves latent load on the low



temperature rink chiller system. A desiccant unit supplies air at a 10°F to 20°F dew-point to control the infiltrated moisture load and condition outside ventilation air. A normal, occupied small recreational arena requires approximately 50 lbs. per hour water removal rate exclusive of any outdoor ventilation air. This load must be added to outdoor air moisture load. Generally, during humid weather, each 1,000 CFM of outdoor air also introduces 50-60 lbs. per hour of additional moisture load!

Desiccant Dehumidification systems use heat energy to remove collected water vapor from the desiccant (Referred to as "reactivation" or "regeneration"). This energy can be propane, natural gas or electricity. Typically, natural gas will provide the best cost/benefit compared to electricity, but facilities in different geographical regions should compare energy sources to select the most economical fuel source.

## **DESICCANT ADVANTAGES:**

When the desired humidity condition within the arena has been met, this "reactivation" heat energy will simply cycle off to achieve the most economical performance. Because a desiccant unit removes water as vapor, it is **unaffected by cold temperatures**. The ability of desiccant systems to deliver dewpoints below freezing allows arena operators to **minimize the cost** of running the rink refrigeration system while eliminating humidity concerns. Conversely, the reactivation system adds some heat to the dehumidified air stream, but is offset by the cooling effect of the ice sheet.

By contrast, a glycol dehumidification system or packaged refrigerated dehumidification unit is restricted to supply air conditions above a 38°F dewpoint. Lower delivered air temperatures require a defrost system that can actually evaporate water vapor back into the arena while the coil defrosts. Given normal internal loads, inadequately humid conditions will exist in the arena.

The current interest in glycol or brine dehumidification coils offers an interesting perspective to those of us who remember replacing so many ineffective cool/re-heat units over the years. Limited dehumidification without a natural gas service is the attraction. These systems, however add electrical loads and run-time to the expensive rink chilling equipment, negating potential savings. Ice plant compressor rebuild comes much sooner since operating hours significantly increase to accommodate the additional load. Often ignored is the complexity of such a system when compared with a simple packaged ARID-Ice® desiccant dehumidification unit. Tying into the rink ice-plant involves piping, pumps, heat exchangers and complex control schemes to facilitate defrost cycles, and attempt to achieve the lowest leaving temperature in order to attempt to keep fog under control.

An ARID-Ice® unit has **few moving parts, is simple, and reduces electrical loads** by transferring the dehumidification duty and most of the latent load from the ice-plant.

Our new optional *Dewpoint Control System* takes the guesswork out of unit operation and prevents over-drying the space, so gas utilization is less. This system corrects the major reason too many arena managers perceive that they have high gas bills, which is setting the humidistat too low.

Even more savings can be realized with our new *Reactivation Heat Recovery* module which recovers some of the reactivation outlet heat to reduce fuel burn.

Why not contact us for more information? We've dehumidified lots of rinks like yours!